

Symbol pomieszczenia	Projektowa temperatura w pomieszczeniu [°C]	Projektowe obciążenie cieplne pomieszczeń [W]
KL. 1A	8	0
KL. 1B	8	0
1	20,0	201
2	20,0	788
3	20,0	715
4	24,0	354
5	20,0	1032
6	20,0	170
7	24,0	288
8	20,0	500
9	20,0	924
10	20,0	217
11	20,0	1018
12	24,0	323
13	20,0	591
14	20,0	775
15	20,0	217
16	20,0	775
17	20,0	591
18	24,0	323
19	20,0	1018
20	20,0	170
21	20,0	924
22	20,0	500
23	24,0	288
24	20,0	201
25	20,0	1005
26	24,0	315
27	20,0	643
28	20,0	788
101	20,0	137
102	20,0	690
103	20,0	611
104	24,0	312
105	20,0	925
106	20,0	138
107	24,0	255
108	20,0	401
109	20,0	744
110	20,0	162

111	20,0	924
112	24,0	288
113	20,0	487
114	20,0	679
115	20,0	162
116	20,0	679
117	20,0	487
118	24,0	288
119	20,0	924
120	20,0	138
121	20,0	744
122	20,0	401
123	24,0	255
124	20,0	137
125	20,0	898
126	24,0	273
127	20,0	539
128	20,0	690
201	20,0	197
202	20,0	788
203	20,0	724
204	24,0	352
205	20,0	1121
206	20,0	168
207	24,0	283
208	20,0	501
209	20,0	922
210	20,0	214
211	20,0	1096
212	24,0	317
213	20,0	591
214	20,0	775
215	20,0	214
216	20,0	775
217	20,0	591
218	24,0	317
219	20,0	1096
220	20,0	168
221	20,0	922
222	20,0	501
223	24,0	283
224	20,0	197
225	20,0	1085
226	24,0	308
227	20,0	644
228	20,0	788