

Symbol pomieszczenia	Projektowa temperatura w pomieszczeniu [°C]	Projektowe obciążenie cieplne pomieszczeń [W]
KL. 7A	8	0
KL. 7B	8	0
1	20,0	210
2	20,0	863
3	20,0	489
4	24,0	337
5	20,0	1045
6	20,0	187
7	20,0	973
8	20,0	403
9	24,0	296
10	20,0	177
11	20,0	974
12	24,0	339
13	20,0	459
14	20,0	863
15	20,0	210
16	20,0	863
17	20,0	459
18	24,0	339
19	20,0	1010
20	20,0	187
21	20,0	973
22	20,0	403
23	24,0	296
24	20,0	177
25	20,0	1128
26	24,0	392
27	20,0	521
28	20,0	863
101	20,0	141
102	20,0	718
103	20,0	385
104	24,0	281
105	20,0	888
106	20,0	139
107	20,0	831
108	20,0	310
109	24,0	245
110	20,0	109

111	20,0	817
112	24,0	283
113	20,0	355
114	20,0	718
115	20,0	141
116	20,0	718
117	20,0	355
118	24,0	283
119	20,0	853
120	20,0	139
121	20,0	831
122	20,0	310
123	24,0	245
124	20,0	109
125	20,0	971
126	24,0	336
127	20,0	417
128	20,0	718
201	20,0	141
202	20,0	718
203	20,0	385
204	24,0	281
205	20,0	888
206	20,0	139
207	20,0	831
208	20,0	310
209	24,0	245
210	20,0	109
211	20,0	817
212	24,0	283
213	20,0	355
214	20,0	718
215	20,0	141
216	20,0	718
217	20,0	355
218	24,0	283
219	20,0	853
220	20,0	139
221	20,0	831
222	20,0	310
223	24,0	245
224	20,0	109
225	20,0	971
226	24,0	336
227	20,0	417
228	20,0	718
301	20,0	186

302	20,0	819
303	20,0	465
304	24,0	323
305	20,0	1059
306	20,0	170
307	20,0	981
308	20,0	376
309	24,0	278
310	20,0	153
311	20,0	976
312	24,0	319
313	20,0	429
314	20,0	819
315	20,0	186
316	20,0	819
317	20,0	429
318	24,0	319
319	20,0	1012
320	20,0	170
321	20,0	981
322	20,0	376
323	24,0	278
324	20,0	153
325	20,0	1130
326	24,0	372
327	20,0	493
328	20,0	819